



PW Laboratories, Inc.

6544 Fremont Road - East Syracuse, New York 13057

Office 315.437.1420 ~ Fax 315.503-3058 ~ pwlabinc@hotmail.com

Sieve Analysis of Soil / Aggregate

Project Title: Laboratory Testing

Project #: L-22019

Test Method: ASTM D422 & D1140

Report #: 6

Report Date: May 3, 2022

Source: T.H. Kinsella, Inc. - Jamesville, NY		Sieve Size - Percent Passing Sieve														
Lab I.D. #	Sample I.D.	1"	3/4"	1/2"	3/8"	1/4"	#4	#10	#30	#40	#60	#100	#200			
42425	#1 & #2 Stone Blend	100	90.1	38.2	18.3	2.3	1.2	1.1	1.1	1.0	1.0	0.9	0.8			

Sample mass, as received, meets minimum mass requirements of test method: Yes X No _____

Performed By: Mark Santorelli

Checked By: Patrick Edmiston

Remarks: _____

Prewashed

Entire Sample X

Mass Retained on #200 Only _____

Not Prewashed: _____